

From: [McAteer, Mike](#)
To: [Mason, Steve](#)
Subject: RE: What I put in FEMA SitRep Input this morning
Date: Monday, August 28, 2017 8:47:08 AM
Attachments: [image002.png](#)
[image003.jpg](#)
[image004.jpg](#)

Is anyone from TCEQ or EPA going to look at this or is it all "fixed" now?



From: Mason, Steve
Sent: Monday, August 28, 2017 8:32 AM
To: McAteer, Mike
Subject: RE: What I put in FEMA SitRep Input this morning
Added this to the FEMA SitRep Input from the 0800 EPA SitRep

On Sunday, August 27, 2017, the City of Corpus Christi reported a sewage overflow into the La Volla Creek from the lift station at the City of Corpus Christi's Greenwood Wastewater Treatment Plant, on Saturday, August 26, 2017, due to a power outage. It is estimated the spill resulted in a discharge of approximately 100,000 gallons of domestic wastewater into the adjacent area. City crews responded to the spill area and the City has contacted appropriate officials, including the TCEQ's Regional office.

With Regards, Steve



From: Mason, Steve
Sent: Monday, August 28, 2017 8:05 AM
To: McAteer, Mike <mcateer.mike@epa.gov>
Subject: What I put in FEMA SitRep Input this morning

EPA, in support of State activities, will initiate contact with industrial sources located within the storm impacted areas to determine operational status and plans to resume operations. EPA will closely monitor start-up of industrial sources after the organized shut-down of their operations.

EPA has initiated its Crisis Communication Plan to ensure rapid response to providing coordinated, accurate, up-to-date information regarding its field activities.

With Regards, Steve

